


# SYNERGIES & SYSTEMS THINKING


MLK / PUTNAM AVE SCHOOL, CAMBRIDGE MA

- Rainwater Capture & Reuse
  - 2x 10,000 tanks & Greywater System
  - +85% Potable Water Use Reduction
  - \$ - Cost Neutral

TRADITIONAL RAINWATER:



RAINWATER AT MLK:



# NEXT CHALLENGE

TOBIN SCHOOL, CAMBRIDGE, MA




**WASTE PIT**




# STORMWATER

## REGIONAL CONTEXT AND RESILIENCE




CURRENT 100-YEAR STORM



2070 100-YEAR STORM

# STORMWATER


2070 100-YEAR STORM PRECIPITATION AND STORM SURGE



---


# STORMWATER

STORAGE AREA



# STORMWATER

FLEXIBLE STRATEGIES TO OVERCOME URBAN CHALLENGES



KING OPEN SCHOOL



KING OPEN SCHOOL



NORTH CORRIDOR, MIT




MLK SCHOOL

# ENERGY + ENVELOPE




# TARGETED DESIGN EFFORT


IN HONOR OF PI DAY




**Classroom Building**



**Office Building**




**Lab**




**Multi-Family**

# TARGETED DESIGN EFFORT

## Baseline Model



## High Efficiency Building



# PASSIVE STRATEGIES



---

# WEST ELEMENTARY

**Location:** Washington, DC

**Use:** Elementary School

**Square Footage:** 90,000 sf


**Floors:** 2



# STARTING FAÇADE DESIGN RIGHT




USE DATA TO INFORM WWR

WINDOW TO  
WALL RATIOS



# STARTING FAÇADE DESIGN RIGHT

THEN ADD SHADING



# STARTING FAÇADE DESIGN RIGHT

THEN ADD SHADING

Design Explorer

Get Data



BAA Classroom Study\_NW 5th Floor

07-24-2017


Reset Selection Exclude Selection Zoom to Selection Save Selection to File My Static Link Tutorial Services Info

Setting L M S

© 2017 Thornton Tomasetti




Sort by: WWR



# STARTING FAÇADE DESIGN RIGHT

BUT ONLY WHERE NECESSARY



Insight 360

---

# BOSTON ARTS ACADEMY (BAA)

**Location:** Boston, MA

**Use:** High School – Arts

**Number of Students:** 500

**Square Footage:** 153,000 sf

**Floors:** 5



---

# PROVING THE IDEAL WALL


- Owner/OPM request VE to exterior wall type w/4” exterior insulation + cavity insulation in lieu of basis of design 6” exterior insulation
- WUFI/THERM analysis shows risk of water in cavity with VE wall

Run the analysis to prove **BETTER PERFORMANCE & REDUCED RISK.**


# PROVING THE IDEAL WALL

USING HYGROTHERMAL ANALYSIS TO JUSTIFY EXTERIOR CONTINUOUS INSULATION

CURRENT STANDARD




## SHEATHING LAYER





### OPTION 3 - 2" WOOL/6" FIBERGLASS

Option 3	Start	End	% red	Min	Max
Gypsum Sheathing	0.35	6.95	189%	0.16	8.36

## BATT INSUL LAYER



RECOMMENDED



### OPTION 1 - 6" WOOL

Option 1	Start	End	% red	Min	Max
Gypsum Sheathing	0.35	0.21	40%	0.15	2.11

---

# YARDS PARCEL I

**Location:** Washington, DC

**Use:** Multi-Family


**Square Footage:** 517,000 sf

**Floors:** 11




# DON'T LISTEN TO RULES OF THUMB

HORIZONTALS MAY WORK BETTER ON EAST/WEST



**\* 37% Less Heat Gain**



# ACTIVE STRATEGIES



---

# ALTERNATIVE “FACTS” ABOUT GROUND SOURCE HEAT PUMPS


---

# ALTERNATIVE “FACTS” ABOUT GROUND SOURCE HEAT PUMPS

- They are renewable energy
- They require a lot of maintenance
- You can't use them if you have a high water table
- The payback is 100 years
- They make your building sustainable

# SYSTEM COMPARISON


GROUND SOURCE HEAT PUMPS - FULL LOAD



Ground source heat pump  
150 wells  
79,000 sf field  
*Soils remediation  
(piping & well drilling)*

# SYSTEM COMPARISON

GROUND SOURCE HEAT PUMPS - REDUCED LOAD




Improved  
Windows

Ground source heat pump  
140 wells (*10 fewer*)  
73,000 sf field  
*Soils remediation*  
*(piping & well drilling)*

# SYSTEM COMPARISON


25% GROUND + 75% AIR SOURCE HEAT PUMPS



No Ground source heat pump  
0 wells

# SYSTEM COMPARISON

25% GROUND + 75% AIR SOURCE HEAT PUMPS



# SYSTEM SELECTION PROCESS

System Options			Indoor Environment 15%				Energy 15%		Cost 25%		Operations 30%						Bldg Impact 15%		Rating Averaged by Category		Weighted Rating		
			Thermal Comfort	Acoustics	Fast Response	Air Quality (Ventilation)	Low Transport Energy	Low Heating & Cooling Energy	Low 1st Cost	Low Life-Cycle Cost	Reliability	Maintainability	Life Expectancy	Ease of Commissioning	Redundancy	Simplicity	Controllability	Floor to Floor Limitations					Floor Area Needed, esp @ 1st Fl
<b>OPTION 1: Water-cooled Chillers, Condensing Boilers</b>																							
1 (62.1 vent)	Central Heating / Cooling Equipment	Water-cooled Chillers Heat Recovery Chiller Condensing Boilers CHW and HW coils	3	2	3	2	1	1	2	2	2	2	3	2	2	2	3	3	1	1.96	3	2.01	3
	Ventilation System <sup>Note 1</sup>																						
	Classroom/Dance zone equipment	FCU's plus Displacement Ventilation <sup>Note 3</sup>																					
	Lab zone equipment <sup>Note 2</sup>	Ceiling mounted FCU's																					
1a (550 ppm)	Central Heating / Cooling Equipment	Water-cooled Chillers Heat Recovery Chiller Condensing Boilers CHW and HW coils	3	3	3	3	0	0	2	1	3	3	3	3	2	3	3	1	1	1.67	5	1.83	4
	Ventilation System <sup>Note 1</sup>																						
	Classroom/Dance zone equipment	All air displacement ventilation <sup>Note 3</sup> with reheat																					
	Lab zone equipment <sup>Note 2</sup>	All air, mixed system																					
<b>OPTION 2: Air-source Heat Pumps, Dx/Gas Ventilation</b>																							
2 (62.1 vent)	Central Heating / Cooling Equipment	Air-source Heat Pumps with VRF units DX cooling coil + gas or VRF preheat	3	2	2	2	2	2	3	2	1	1	2	2	3	2	1	1	3	2.09	2	2.08	1
	Ventilation System <sup>Note 1</sup>																						
	Classroom/Dance zone equipment	Ceiling mounted VRF units with mixed air																					
	Lab zone equipment <sup>Note 2</sup>	Ceiling mounted VRF units with mixed air																					
<b>OPTION 3: Ground-source Heat Pumps + DX/Gas Ventilation</b>																							
3 (62.1 vent)	Central Heating / Cooling Equipment	Water-source Heat Pumps with VRF units Vertical closed-loop geothermal wells	3	2	3	2	2	3	1	1	2	2	2	2	3	2	2	3	2	2.13	1	2.02	2
	Ventilation System <sup>Note 1</sup>	Water-source DX cooling coil + gas preheat																					
	Classroom/Dance zone equipment	Ceiling mounted watersource VRF units with mixed air																					
	Lab zone equipment <sup>Note 2</sup>	Ceiling mounted watersource VRF units with mixed air																					
<b>OPTION 4: Ground-source Heat Pumps + CHW/HW Ventilation</b>																							
4 (62.1 vent)	Central Heating / Cooling Equipment	Ground source Chiller-Heater Plant (Vertical closed-loop geothermal wells) CHW and HW coils	3	2	3	2	2	2	0	1	1	1	3	2	2	1	2	3	1	1.74	4	1.61	5
	Ventilation System <sup>Note 1</sup>																						
	Classroom/Dance zone equipment	Floor mounted FCU's with displacement ventilation <sup>Note 3</sup>																					
	Lab zone equipment <sup>Note 2</sup>	Ceiling mounted fan coil units with mixed air																					
4a (550 ppm)	Central Heating / Cooling Equipment	Ground source Chiller-Heater Plant (Vertical closed-loop geothermal wells) CHW and HW coils	3	3	3	3	0	1	0	1	1	2	3	2	2	1	2	1	1	1.37	6	1.36	6
	Ventilation System <sup>Note 1</sup>																						
	Classroom/Dance zone equipment	All air displacement ventilation <sup>Note 3</sup>																					
	Lab zone equipment <sup>Note 2</sup>	All air, mixed system																					



---

# BENCHMARK

	<b>MSBA</b>	<b>BAA</b>
<b>Ext.</b>	<b>14.01%</b>	<b>15.24%</b>
<b>HVAC</b>	<b>14.37%</b>	<b>10.77%</b>
<b>Total</b>	<b>28.38%</b>	<b>26.01%</b>

---

## RESULTS


- **Savings in HVAC balances cost in exterior envelope**
- **Reduced HVAC Equipment = Reduced Maintenance**
- **Invest in items that last (50 yr vs 20 yr)**
- **Passive Survivability**

# INDOOR ENVIRONMENT



# PREDICTIVE ANALYSIS

## DAYLIGHT/WWR TARGETS SET PER ROOM



Ladybug/Honeybee

# PREDICTIVE ANALYSIS

## TRACKING FAÇADE DESIGN AS IT PROGRESSES



SOUTHEAST - Current Design



SOUTHEAST - Improvement 1





SOUTHEAST - Improvement 2

	Window to Wall Ratio (actual)	Window to Wall Ratio (target)	Over/Under	Linear Feet of Window needed	Shading Needed
<b>5th Floor</b>					
Band/Recital Hall	0.40	0.3	0.10	-13.5	Y
Recording Studio	0.19	0.3	-0.11	6.3	N
MIDI Lab	0.30	0.3	0.00	1.0	N
Music Teach Plan	0.80	0.2	0.60	-11.8	Y
Classroom 1	0.53	0.3	0.23	-7.8	Y
Classroom 2	0.26	0.4	-0.14	7.5	N
Classroom 3	0.26	0.4	-0.14	7.5	N
Project Classroom	0.41	0.3	0.11	-8.2	Y
Small Group	0.80	0.3	0.50	-9.0	N
Classroom 4	0.19	0.3	-0.11	12.1	Y
Classroom 5	0.26	0.5	-0.24	12.1	Y
Corridor	0.13	0.2	-0.07	2.6	N
Stairwell	0.08	0	0.08	-5.0	N
Choral	0.34	0.3	0.04	-1.5	Y
M Practice	0.15	0.2	-0.05	2.0	Y
Small Ensemble	0.20	0.3	-0.11	4.2	Y
Percussion	0.31	0.3	0.01	0.8	Y
Piano Lab	0.27	0.3	-0.03	2.2	Y
L Practice	0.14	0.2	-0.06	2.3	Y
Large Ensemble	0.23	0.2	0.03	-1.5	Y

Insight 360

# PREDICTIVE ANALYSIS


## VERIFYING INTERIOR CONDITIONS



Ladybug/Honeybee

# POST-OCCUPANCY EVALUATIONS

## CO2 LEVELS




THE IMPACT OF GREEN BUILDINGS ON  
**COGNITIVE FUNCTION**

City of Cambridge, MLK School  
Perkins Eastman

# QUESTIONING CALCULATIONS

## AIR QUALITY (BAA CO2 CONVERSATIONS)



## ASSUMPTIONS

Classroom occupancy: 22 people

Classroom size: 900 square feet, 10 feet floor to ceiling height

Ventilation Effectiveness: 1.2 (displacement ventilation)

Ambient CO2 Concentration: 450 ppm

Occupant metabolic rate: 1.0 (seated, quiet)

ASHRAE 62.1 Minimum ventilation: 7.5 cfm/p + 0.06 cfm/sf

- Engineer Occupant Load based on area = 3000 occupants
- Actual Occupancy: 640 Students, 150 Staff = 790 Occupants
- 6 AHU to 3
- What is your design load for Code?
- What is your design load for 550 ppm in Classrooms?

# POST-OCCUPANCY EVALUATIONS

## ACOUSTICS

All schools tested designed to LEED acoustics prerequisite

Average

52 dBA

Peak

>80 dBA

Satisfaction Rate

30%



**BAD NOISE LEVELS**

I can not  
pay attention.

---

## CONCLUSIONS

# WHERE TO NEXT?

# THANK YOU

Dan Arons

[d.arons@perkinseastman.com](mailto:d.arons@perkinseastman.com)

Heather Jauregui

[h.jauregui@perkinseastman.com](mailto:h.jauregui@perkinseastman.com)

Jana Silsby

[j.silsby@perkinseastman.com](mailto:j.silsby@perkinseastman.com)

